



Weymouth Township School District

Dr. John B. Alfieri, Superintendent
alfieri@weymouthtsd.org
Patricia Palmieri, Business Administrator
palmieri@weymouthtsd.org
1202 Eleventh Avenue
Dorothy, NJ 08317
(609) 476-2412 – Phone
(609) 476-3966 - Fax

October 2, 2017

As you may recall, last spring, the Weymouth Township School District was required to test all water access points (fountains, sinks, etc.) for lead levels. Following the state protocols such testing was completed. On May 18, 2017, my predecessor informed you via letter that two access points in the entire building tested at a level higher than allowable. The first was Room #103, the second was Room #111.

Shortly thereafter, attempts were made to remediate these two lead issues. The remediation included, but was not limited to: removal of piping, flushing the system, replacing fixtures, etc. As required by code, these two locations were retested on August 21, 2017.

- ✓ We recently received the results of the lead-level testing this past week. Room #103 dropped from 23.7 ppb (15.0 is acceptable) to 4.6 ppb. We feel that this location is now safe for all children and adults.
- ✓ Room #111 originally tested at 23.7 ppb and the second test resulted in a lead level of 15.3 (again, 15.0 is acceptable). Yes, this is very close, but it is not acceptable. As a result of this outcome, Room #111 (Computer Lab,) will have the fixture in this classroom removed forthwith and shut off permanently. As this class is only used by each student one period per week, we feel that this solution makes the most sense at the current time.

Any of the formal data justifying these results can be found on file in the Board Office. Should you have any questions, comments, or concerns, please feel free to contact me or Ms. Patricia Palmieri, our School Business Administrator.

Sincerely,


John B. Alfieri, Ed. D.
Superintendent